

PIT THERMAL ENERGY STORAGE UPDATE FROM TOFTLUND 85.000 M3



AGENDA

- Introduction
 - Key facts
 - Main experiences
 - Update on the performance



KEY FACTS

Fact			
Put in operation	June 2017		
Size	85.000 m3		
Charging capacity	18 MW		
Discharging capacity	8 MW		
Heat source	Primarily solar thermal and heat from a 3 MW absorption heat pump operated with heat from a gas fired boiler or an electrical boiler. Absorption heat pump cools down the storage in the winter period. Indirectly heat from CHP (7,2 MWheat).		
Lid construction	1,5 mm HDPE liner as top liner Insulation – 600 mm Leca (Expanded clay) 2,5 mm HDPE liner as floating cover		





MAIN EXPERIENCES

- Permanent floating liner should not be installed before water filling

 a sacrificing liner should be used instead Weight pipes should be avoided.
- Lid construction works as intended,
 - Approx. 2/3 of the insulation was flooded in the commissioning phase, due to a heavy shower storm. In the following phase it has shown possible to completely dryout the insulation and the insulation properties is restored without replacement of the insulation material.
 - For the next project with a lid construction with Leca, the lid should be installed with ventilators, for a more controlled ventilation of the insulation. Primarily to handle the water vapour diffusion from the storage.

Drainage system works satisfactorily in accordance to the operator.

• Some puddles needs to be drained manually, but in general the system works automatically.









UPDATE ON THE PERFORMANCE

DATA FROM TOFTLUND (85.000 M3 STORAGE/27.000 M2 SOLAR/CHP/EL BOILER/GAS BOILER)



Total realized heat loss

- 4.400 MWh in 2018 wet insulation rainwater entered the lid construction during the commissioning phase.
- 2.800 MWh in 2019 active drying of the insulation until April/May.
- 2.321 MWh latest 12 month. corresponding to the design.

Calculated heat loss

Approx. 2.650 MWh/year – calculated based on the operating profile for 2019.



UPDATE ON THE PERFORMANCE

DATA FROM TOFTLUND (85.000 M3 STORAGE/27.000 M2 SOLAR/CHP/EL BOILER/GAS BOILER)

Period	01-02-2018 to 31-01-2020 (2 years)	Last 12 mth. (01/10/2019- 30/09/2020)
Energy to the storage	17.141 MWh	8.501 MWh
Energy out of the storage	9.874 MWh	6.098 MWh
Heat losses	7.027 MWh	2.321 MWh
Efficiency	58 %	72 %

The heat loss has the last 4-5 month stabilized at the current level of 2.300 MWh, when seen 12 month back.

Conclusion: The storage is now performing in accordance to the design.







